

Declaration of Rating Revision

FMCC hereby notifies all relevant stakeholders that, following a comprehensive evaluation and compliance verification in accordance with AS/NZS 60335.2.40, the electrical rating of the multi-split system listed below has been officially revised to **32A**, applicable exclusively to Hi-Wall indoor unit combinations.

This revision is based on validated test results and reflects our continued commitment to product safety, regulatory compliance, and adherence to applicable standards. Updated rating labels reflecting this change will be applied to the affected units in due course.

Models Subject to This Revision

- **38QUM190D8S6**
- **38QUM170D8S5**

We strongly recommend that installers, distributors, consultants, and end users refer to the latest technical documentation and equipment nameplate information when undertaking system design, installation, commissioning, or project planning activities.

Should you require any additional information, supporting documentation, or technical clarification regarding this rating revision, please contact your designated FMCC representative or our customer support team.

We sincerely appreciate your continued trust and partnership. FMCC remains committed to delivering high-quality products and maintaining the highest standards of safety, performance, and customer satisfaction.

Thank you for your support.